

780 CMR 9.00 FIRE PROTECTION AND LIFE SAFETY SYSTEMS

780 CMR 907.0 Fire Alarm and Protection Systems

...

907.9.1.4 Group R-2. In Group R-2 occupancies required by 780 CMR 907.0 to have a fire alarm system, all dwelling units and sleeping units shall be provided with the capability to support visible alarm notification appliances in accordance with ~~ICC A117.1~~ **521 CMR**.

...